



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

January 16, 2014

KOHLER COMPANY  
P & S P  
DANIEL J. BARTZ  
444 HIGHLAND DRIVE  
KOHLER WI 53044

Re: Description: URINAL  
Manufacturer: KOHLER COMPANY  
Product Name: BARDON TOUCHLESS URINAL  
Model Number(s): K-4915  
Product File No: 20130295

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.41 (3) (a) and 384.20 (4) (b) 8. , Wis. Adm. Code based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2019.

This approval supersedes the approval issued on January 23, 2009 under product file number 20090024.

This alternate approval is required because the vacuum breaker serving the flush valve is not listed as conforming to ASSE 1001.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Environmental Engineer - Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 267-9723 Fax  
glen.schlueter@wi.gov E-mail